No. 25 CFO BNG-East Advice School 2028

Office of the Chief Fire Office Bangalora East Kamataka State Fire & Emergency S No. 4. Bahas Shavan Road. BANGALORE - 560 025 Dated: 02-01-2024

To
The Authorised Signatory.
M.s. Jain School.
Bharath Nagar, BEML Nagar,
DK Halli, Robertsonpet Hobli,
KGF, Bangarpet Taluk,
Kolar District-563 115.

Sir.

Sub: Issue of Advice on requirement of fire prevention, fire fighting & evacuation measures for Jain School, Sy. No.05, Bharath Nagar BEML Nagar, DK Halli, Robertsonpere Hobli, KGF, Bangarpete Taluk, Kofar District 563115

Ref: Report No. 5/School/DFO/KLR/2023Dated: 27-12-2023

→@@@←

With reference to the subject cited above, the District Fire Officer, Kolar Fire Station has from fire prevention, fire fighting and evacuation point of view inspected the premises of XI. John School, Sy. No.05, Bharath Nagar, BEML Nagar, DK Halli, Robertsonpet Hohli, Keir Bangarpete Taluk, Kolar District-563115 on 27-12-2023 for suggesting fire prevention, fir fighting and evacuation measures. The details are as follows:--

A Details of the building Address of the premises

BEML Nagar DK halli KGF Hobli Bangarpete Tq, KGF 563115

Number of building

Two building.

Number of floors

Ground & 01 upper floors : 2rd Building.
Ground floor &02 upper floors

Floor wise details of occupancy:
1st Building

Circund floor

14 class rooms, 01 reading room, 01 staff noom 01 office room, 01 principal room, 04 rest noom separated for girls & boys

14 Class rooms, Store room .01 laborators .01 librar. .03 rest room separated for girls & boy

I' floor

2nd building

Ground floor

Admin office & trustee office.

1" floor : Library .. 2" floor : Record room .

Height of the building

: 1 st building 06 mtrs 2nd building 09mtrs

60 Site area : 8299,07Sq. mtrs.

Built up area as per plan :-

Ist building

Ground floor

: 8.74.79 Sq.mtrs.

1st floor

: 895.5.92 Sq.mtrs.

2nd building

Ground floor

: 223.05 Sq.mtrs.

1º floor

: 223.05 Sq.mtrs.

204 floor

: 223.05Sq .mtrs

8 Type of construction : RCC Building.

Surroundings:-

East

Residential Building

West

: Residential Building

North

: 06 mtrs wide road

South

: Residential Building .

Name and address of the building owner

: Secretary

Bantia Education social cultural & welfare trus

Tulasi Nivas ,Arihant Marg jain colony

Robertsonpete KGF 563122.

11. Name and address

of applicant

: Secretary

Jain school Bharath nagar Beml nagar. DK ha

Bangarpete Tq .KGF 563115

Number of students 12

370 Students and Teaching staff-19. Non teaching staff - 06.

B. On inspection of the school premises, the following fire protection, fire fighting and evacuation measures were existing and are as follows.

	Details (1)	Existing (2)	Remarks (3)
-	Approach to the premises	The premises is accessible from 12 mtrs wide road located on the western side.	The requirement is complied with
	Entrance to premises	03 entrances, each of minimum 6.00 mtrs, width on the Nothern side has been provided.	The requirement is complied with.
4.	Width of open space	East: 06.00 mtrs. West: 06.00 mtrs. North: 06.00 mtrs. South: 06.00 mtrs.	The setbacks allowed all around the building shall be maintained free from any construction or obstruction for the easy movements of emergency vehicles.
5.	Number of Stair cases	02 staircases each of 1.5 mtrs. width have been provided.	The requirement is complied with
6.	Portable Fire Extinguishers	Provided 02 nos. ABC powder extinguisher of 2 kgs. capacity. 01 nos. ABC powder extinguisher of 5 kgs. capacity.	fire extinguishers of 00 kgs. capacity
7.	Fixed Fire fighting installations.	Not provided	Hose reel hose of 19 mm size and a adequate length to reach the farther point of each floor for every 100 Sq.mtrs. near each staircase shall to provided with a shut off branch. The system should be connected to overhead tank of 10,000 litres capacity with one electrically driven pure
8.	Escape route	Not marked	capable of delivering 450 litres water per minute. Directions in which the students hat to move in the event of any emergen have to be indicated in the corridor each floor during evacuation. It shows

9. First Aid Box

6 First Aid Boxes have been provided.

06 nos, more first aid boxes shall be provided in each floor.

10. Fire order

Not Displayed

A notice board written in bold indicating the action to be taken by the employees in case of any emergency should be displayed near each stair case at each floor. The notice board should contain the telephone number of the KGF Fire Station i.e. 08153-266000.101, and of nearby ambulance service.

11. Training to employees staff Not trained

At least 40% of the staff shall be get trained in fire prevention Fire fighting, evacuation measures at R.A Mundkar Fire & Emergency Service Academy, Bangalore.

Ender the circum stance stated above, there is No Objection to run Education activities in your school building subject to the condition of providing additional fire fighting equipment and fire precautionary measures shown in column No.3 of part B. Therefore, the school management should comply Karnataka Fire & Emergency Services Department conditions to provide additional equipments and then intimate to this office within 3 months positively without that This Fire Advisory Certificate valid for only one year from the date of issue and renewable.

Yours faithfully.

CHIEF PIRE OFFICER
Bangalore East

Kamataka State Fire & Emergency Servi BANGALORE - 560 025.

Copy to District Fire Officer, Kolar Fire Station.